

**NAVFAC  
SPECIFICATION**

**WO 6059431/6059433  
CP1304M/CP1305R  
REPAIRS AND  
IMPROVEMENTS TO  
BEQ B-4169**

**MCAS Cherry Point, NC**

**AMENDMENT #0011**

## **IMPORTANT**

**This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.**

**If your proposal has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to proposal opening time.**

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE 1	OF PAGES 2
2. AMENDMENT/MODIFICATION NO.  0011	3. EFFECTIVE DATE  12/19/2014	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)  6059431/6059433		
6. ISSUED BY  <b>CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533</b>		Code N40085	7. ADMINISTERED BY (If other than item 6.)	Code	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)  <b>AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL</b>			<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION Repairs & Improvements BEQ B-4169	
			<input type="checkbox"/>	9B. DATED (SEE ITEM 11)	
			<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
			<input type="checkbox"/>	10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE				

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers  is extended  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor  is not  is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

WO6059431/6059433, CP1304M/CP1305R; Repairs & Improvements BEQ B-4169, MCAS Cherry Point, NC

The purpose of this amendment is to incorporate the attached changes.

Proposals must be sent electronically to the following two (2) email addresses:

roicc\_chpt\_ktr\_bids@navy.mil  
jennifer.L.stewart1@navy.mil

**Proposals are due to the above email addresses by 1400 Thursday 08 January 2015.**

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Amendment 11  
RFI Responses - BEQ 4169

1. In amendment #9 section 01 35 26 page 4 paragraph 1.6.1.1.1 Contractor Quality Control (QC) Person indicates the said person cannot be the SSHO. Section 01 45 00.00 20 paragraph 1.5.1.1 Duties of QC is only to implement the QC program. Does the site superintendent have to be a separate person or can the SSHO or QC be the Superintendent?

**Bid per the specifications. The Government wants a separate person each for the duties of superintendent, SSHO and QC.**

2. On drawing CS-501 per Sect. "H", there is a reference to several sleeves with locking caps for removable bollards. There appear to be (6) of them, Item #8 on drawing CS-101. I can't find a detail of those removable bollards or the sleeves with the locking caps. Can you steer me in the direction to find them. I have seen something like these before on other jobs and the design/solution was an expensive item. Thanks for any help you can find.

**The Contractor shall pick a bollard system (bollard & sleeve system) based off specifications listed on drawing CS-501 Section H.**

3. The note on the door schedule about all exterior doors meeting the requirements of: ASTM F2247 Category 3 explosion weight 2. A lot of these doors are going into existing frames that will not qualify for?

**All doors must meet ATFP. Bid the project per drawings and specifications.**

4. The hardware schedule does not have the doors on it but has a bunch of door numbers on it that are not on this door schedule.

**All information is in the door hardware schedule in section 08 71 00 of the specifications**

5. Drawing A-605 , sign type J calls for a raised pictogram for the USMC Eagle, Globe and Anchor. There is too much detail for this to be raised. Will subsurface print be acceptable?

**Bid the project per the drawings and specifications.**

6. It appears that there is extensive water damage and framing issue in the Existing Soffit, the workmanship of the North and South side are not the same; please advise what is the extent of work to be performed in these areas?

**Soffit vent anchoring addressed in previous amendment.  
Refer to sheet A-201 for gutter repair and new coat/finish on soffit and fascia.**