

**NAVFAC
SPECIFICATION**

**WO 6059431/6059433
CP1304M/CP1305R
REPAIRS AND
IMPROVEMENTS TO
BEQ B-4169**

MCAS Cherry Point, NC

AMENDMENT #0005

IMPORTANT

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.

If your proposal has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to proposal opening time.

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		1. CONTRACT ID CODE	PAGE 1	OF PAGES 3
2. AMENDMENT/MODIFICATION NO. 0005	3. EFFECTIVE DATE 07/18/2014	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 6059431/6059433	
6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533		Code N40085	7. ADMINISTERED BY (If other than item 6.) Code	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL		<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION Repairs & Improvements BEQ B-4169	
		<input type="checkbox"/>	9B. DATED (SEE ITEM 11)	
		<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
		<input type="checkbox"/>	10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers is extended is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

WO6059431/6059433, CP1304M/CP1305R; Repairs & Improvements BEQ B-4169, MCAS Cherry Point, NC

The purpose of this amendment is to incorporate the attached information.

See Attached.

Revised Drawings are available via the following link:

<https://www.fbo.gov/fedteds/N400856059431>

The proposal due date is extended to Wednesday 23 July 2014.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

SPECIFICATIONS

DIVISION 00 - PROCUREMENT AND CONTRACTING REQUIREMENTS

SECTION 00 01 15 - LIST OF DRAWINGS

NAVFAC DRAWING NUMBERS; 12647677, 12647713, 12647714, 12647715, 12647717, 12647727, 12647728, 12647729, 12647730, 12647731, 12647732, 12647733, 12647734, 12647735, 12647737, 12647738, 12647739, 12647741, 12647742, 12647743, 12647744, 12647745, 12647749, 12647751, 12647753, 12647754, 12647755, 12647756, 12647757, 12647758;

Delete drawings listed in their entirety and replace with revised NAVFAC Drawings with corresponding NAVFAC numbers with revision 2 mark, dated 16 July 2014.

NAVFAC DRAWING NO. 12647661; Sheet CD-101;

SPECIFIC WORK ITEMS (THIS SHEET);

ADD NOTE #8; Remove a total of 10 trees of 12" - 24" trunk diameters around building 4169. The tree, trunk and root system needs removed with the damaged areas re-filled of soil, graded and re-sodded. Government will tag which trees are to be removed before demolition work begins.

Detail A; Site Plan-Demolition and Existing Conditions;

Add the circle note 8 with an arrow and leader pointing to the tree areas around on the east and west sides of building 4169.

NAVFAC DRAWING NO. 12647689; Sheet A-410; Detail 1; Enlarged Plan;

Room 147, Janitor;

Change the floor finish to be ETZ-2

NAVFAC DRAWING NO. 12647694; Sheet A-604;

ROOM FINISH SCHEDULE;

145 Fire Alarm; Delete ETZ-3 epoxy terrazzo floor finish. Provide Sealed Concrete as floor finish.

147 Janitor; Change Floor finish to be ETZ-2.

FINISH KEY;

SS-1; STYLE/MODEL DESCRIPTION; Add "SMOOTH HONED FINISH"

SS-2;

STYLE/MODEL DESCRIPTION; Add "SMOOTH HONED FINISH"

COLOR; Add "Multi-Color to be chosen from Manufacturers upper price groups"

SS-3;

STYLE/MODEL DESCRIPTION; Add "SMOOTH HONED FINISH"

COLOR; Add "Multi-Color to be chosen from Manufacturers upper price groups"

NAVFAC DRAWING NO. 12647677; Sheet A-201; REV 2 sheet attached and made part of this amendment;

KEYED CONSTRUCTION NOTES;

Add NEW KEYED CONSTRUCTION NOTE 8; "Repair gutter joints in existing +8" square metal box gutter. Remove existing joint sealant, clean gutter surface and prime to receive new EPDM patch. Provide new EPDM roofing material patch 16" long. Center EPDM on existing joint and install on interior of existing gutter. Lap EPDM up inside of gutter (both sides) 6" minimum and adhere to interior of existing gutter. All gutters and downspouts are to be cleaned of debris, plants and dirt. Any loose portions of the gutter and downspouts are to be anchored to the building structure. All gutter seams are to be repaired per detail 8/A-201."

Detail 8/A-201;

Add this sentence with an arrow and leader pointing to the existing gutter; "All gutters and downspouts to be cleaned of all debris, plants and dirt. Any loose portions of the gutter and downspouts are to be anchored to the building structure."

Detail 8/A-201;

Add note; "Typical all gutter seams" to the end of the existing gutter note.

Details 1,2,3,4/A-201;

Add new keyed note number 8 to all elevations with arrows and leaders pointing to all gutters and downspouts;